

Area of Refuge Signage Specifications

5.0 Graphics

- 5.1 Area of Refuge signs shall state the words "Area of Refuge".
- 5.2 Tactile signage must include both raised letters and Braille.
- 5.3 Add "D" to Area of Refuge illuminated sign (**Part #7050**) for double sided sign.

6.0 Electrical

- 6.1 The Area of Refuge illuminated sign (**Part #7050**) sign shall be 120/277vac and include built-in battery backup.

7.0 Product Substitutions

- 7.1 No substitutions.

8.0 Warranty

- 8.1 The Area of Refuge illuminated signage (**Part #7050**) shall be warranted for a period of two years.

9.0 Manufacturer

The manufacturer shall be:
RATH by AVIRE
N56 W24720 North Corporate Circle
Sussex, WI 53089
800-451-1460
Website: www.avire-global.com/en-us/

